



GENERAL NOTES

1. CONCRETE TO HAVE 3000 PSI MIN. COMPRESSIVE STRENGTH AFTER 28 DAYS.
2. REINFORCEMENT STEEL IS DEFORMED AND MEETS THE REQUIREMENTS OF ASTM A615 GRADE 60.
3. CENTER LINE OF ANCHOR BEAM TO PASS THROUGH CENTROID OF BLOCK.
4. EMBEDDED STEEL TO HAVE A MIN. 3" COVER.
5. WORLD TOWER COMPANY WAS NOT PROVIDED WITH A SITE SPECIFIC SOILS REPORT FOUNDATIONS DESIGNED FOR NORMAL DRY SOILS CONDITIONS IN ACCORDANCE WITH EIA-F FOR A MINIMUM ALLOWABLE SOIL BEARING PRESSURE OF 2000 PSF. NO ALLOWANCE WAS MADE FOR SOFT SOILS, PEATS, ORGANICS, WATER, OR ROCK IN THE EXCAVATION(S).

TITLE:

ANCHOR DETAILS

GREEN MOUNTAIN POWER

SCALE	NONE	DWN.	LKB	CKD.	DATE
FILE					5-21-08
				DWG. NO.	